



Certificate no. TAI-FS-C-24-0090

Product description WE HEREBY CERTIFY THAT
Hydraulic scotch yoke quarter turn spring return and double acting actuator

Models **Series QTHS, QTHS-FA, QTH**

Manufacturer **DVG Automation S.p.A.**
Via Gabriele Rossetti 2
I-29016 Cortemaggiore (PC)

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS
IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Assessment report no. TAI-FS-R-24-0161

Expiry date 02.12.2027

Issue date 03.12.2024

TUV AUSTRIA ITALIA
03.12.2024, Monte Roberto (AN)

Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.
Via del Commercio, 6/A 60030 Monte Roberto (AN)
+39 0731 22781 - info@tuvaustraiitalia.com - tuvaustraiitalia@pec.it
C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
Società a socio unico, soggetta a controllo e coordinamento di:
TÜV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
www.tuvaustraiitalia.com

Annex to certificate no. TAI-FS-C-24-0090

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Series QTHS - No PST	1	1,18E-08	0,00E+00	0,00E+00
Series QTHS - With PST	1	1,06E-09	1,08E-08	0,00E+00
Series QTHS-FA (with 1 QEV) - No PST	1	1,28E-08	0,00E+00	0,00E+00
Series QTHS-FA (with 1 QEV) - With PST	1	1,15E-09	1,17E-08	0,00E+00
Series QTHS-FA (with 2 QEVs in 2oo2) - No PST	1	1,38E-08	0,00E+00	0,00E+00
Series QTHS-FA (with 2 QEVs in 2oo2) - With PST	1	1,24E-09	1,26E-08	0,00E+00
Series QTH - No PST	1	2,76E-08	0,00E+00	0,00E+00
Series QTH - With PST	1	2,48E-09	2,51E-08	0,00E+00


Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: - single channel configuration: - up to SIL 2 without external diagnostic tests - up to SIL 3 considering external diagnostic tests - double channel configuration: up to SIL 3			

Remarks:

- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SCTD-SM-QTHS-01, SCTD-SM-QTH-01

END OF CERTIFICATE

TUV AUSTRIA ITALIA
03.12.2024, Monte Roberto (AN)


 Ing. Crescenzo Di Fratta

TUV AUSTRIA ITALIA S.p.A.
 Via del Commercio, 6/A 60030 Monte Roberto (AN)
 +39 0731 22781 - info@tuvaustraiitalia.com - tuvaustraiitalia@pec.it
 C.F./P. IVA IT01055750333 - Cap. Soc. i.v. € 400.000,00 - REA AN n. 211030
 Società a socio unico, soggetta a controllo e coordinamento di:
 TÜV AUSTRIA HOLDING AG Deutschstrasse 10, A-1230, Vienna, Austria
 www.tuvaustraiitalia.com